



ABINGTON WATER DEPARTMENT

POST OFFICE BOX 2011

ABINGTON, MASSACHUSETTS 02351

TELEPHONE (781) 982-2128

FAX (781) 982-8332

dcallahan@abrockwater.com

COMMISSIONERS

STEVEN D. BRADBURY
CHAIRMAN

JOHN E. WARNER II
SECRETARY

RICHARD D. MUNCEY

DANIEL F. CALLAHAN
SUPERINTENDENT

ABINGTON BOARD OF WATER COMMISSIONERS MEETING:

The Abington Board of Water Commissioners held a meeting on April 8, 2010 at 6:22 p.m. at the Abington Town Hall, 500 Gliniewicz Way, Abington, MA. Present were the following Commissioners:

Steven D Bradbury, Chairman
John E. Warner II, Secretary
Richard D. Muncey

Also:
Daniel F. Callahan, Superintendent
JoAnne Hall, Administrative Assistant

Mr. Warner motioned to accept the minutes from the March 8, 2010 meeting. Mr. Muncey seconded the motion and it was voted two in favor. Mr. Bradbury was not at the meeting and abstained from the vote.

The Board reviewed the Financial Report. Mr. Callahan stated receipts are down but we will make it. Mr. Callahan stated the decrease in receipts are a result of the decrease in pumping stats. Mr. Callahan stated we will not spend more than appropriated. Mr. Warner motioned to approve the Financial Report. Mr. Muncey seconded the motion and it was unanimously accepted.

Mr. Callahan presented the Superintendent's Report. (Copy to follow) Mr. Callahan informed the Board the distribution crew has been very busy working with the highway department due to inclement weather conditions, working at the new building on Centre Avenue, Glenn Sullivan attended an asbestos pipe removal class in Dartmouth, MA, a hydrant break on Plymouth Street and a circumference break on Walnut St. Mr. Callahan informed the Board our articles passed at the town meeting, which was continued until May 10, 2010. Mr. Warner motioned to accept the Superintendent's Report. Mr. Muncey seconded the motion and it was unanimously accepted.

The owner and his representative from 385 North Avenue asked the Board if they could tap into the system before the highway construction in the area is complete. A fifteen thousand square foot building is proposed on the property with a proposed six inch fire service and a minimum of one and a half inch domestic service. The existing building on the property will continue to be serviced by the existing service and a new tap will service the proposed building. The Board discussed a seventy thousand dollar (\$70,000.00) tapping fee for the six inch tap, five thousand five hundred dollar (\$5,500.00) domestic water service charge and a one dollar (\$1.00) per square foot sprinkler development fee. Mr. Bradbury stated he has no issue with it getting done and suggested they get on the agenda for the next meeting. Mr. Warner agreed he had no objection to them tying into the system. Mr. Muncey asked Mr. Callahan to work up a price for the requested tie in.

The Board agreed to set the next monthly meeting date for the Abington Board of Water Commissioners at the Abington & Rockland Joint Board of Water Commissioners meeting to be held immediately following the Abington Board of Water Commissioners Meeting.

At the Abington & Rockland Joint Board of Water Commissioners Meeting, the Board set the next monthly meeting for May 3, 2010 immediately following the Rockland Board of Water Commissioners Meeting at 6:00 p.m. at the Abington Town Hall, 500 Gliniewicz Way, Abington, MA.

Mr. Muncey motioned to adjourn the meeting at 6:51 p.m. Mr. Warner seconded the motion and it was unanimously accepted.



John E. Warner II, Secretary

Date: 5-17-10



ABINGTON WATER DEPARTMENT

POST OFFICE BOX 2011

ABINGTON, MASSACHUSETTS 02351

TELEPHONE (781) 982-2128

FAX (781) 982-8332

dcallahan@abrockwater.com

COMMISSIONERS

STEVEN D. BRADBURY
CHAIRMAN

JOHN E. WARNER II
SECRETARY

RICHARD D. MUNCEY

DANIEL F. CALLAHAN
SUPERINTENDENT

ABINGTON DISTRIBUTION REPORT

April 8, 2010

Fifty main and service markings for Dig Safe.

Worked with Highway Department cleaning catch basins around town after the severe rain storm ending on Tuesday, March 16th and March 30th.

Worked on installing the water service and demolition site work at 366 Centre Avenue.

Replaced hydrant at 800 Plymouth Street.

Repaired circumference break in 12 inch main at the Walnut Street Easement.

Hydrant maintenance.

Serviced all equipment.

Replaced 78 meters with new Neptune Fixed Networking Units.

Delivered shut off notices and read meters for billing.

Respectfully submitted,

Daniel F. Callahan, Superintendent